Planned Outage and Interruption Request

Work Owner _____ Organization _____ Phone _____

Onsite Contact	:Phone	·					
Project #	Custon	ner Request	WO Number	WO Number			
Select Interruption Type:							
	Building Access Control	Elevator	Laboratory Utility	Sanitary Sewer			
Building System Outage or Space Closure	Electric Power	Heating Ventilat A/C (HV	ion & Natural Gas	Domestic Water			
(Only if part of a building is out, Check all that apply)	Building Space/Entrances/ Occupant Flow	Telepho	ne/IT Fumehood	Cooler/Freezer			
- 3-, 3.155. dii dide dppi))	Emergency Power (Life Safety Approval required	Other d) (Explain	below)				
Utility Outage	Electric Power	Natural	Gas Sewer from Building	Domestic Water			
(If entire building is out)	Hot Water (Central Plant)	Chilled \((Central I	Water Steam	Other (Explain Below)			
Outside Closures	Roadway	Sidewall	k Bike Lane	Waste Receptacle			
	Parking Spaces	ADA Fac	ilities Traffic Signal	Other (Explain below)			
Life Safety System Outage (Required any time system or components are taken out of service)	Fire Alarm	Fire Suppres System : Fire Pun	and/or Range Hood	Fire Hydrant			
		Fire watch required? Yes or No (Determined by Risk Management & Safety and University					
Life Safety Notifications	Annual Fire Alarm Test an Inspection	d Fire Suppres System	System Lesting	Fire Alarm System Download			
Notifications	Unplanned Outage	Prevent Mainter		Other (Explain below)			
Description of Work Activity							
Building(s) or Location(s) Affected							
Specific Space Affected (Room Numbers)							
How are the building clients or University stakeholders affected? What will they notice?							
Schedule: Start Date:	Start Time:E	End Date:	End Time:				

Page 1 of 3 R7 7/31/2021

Planned Outage and Interruption Request

Planning Reviews (Per Review Matrix):

Organization	Review Required?	Reviewer	Review Date
Maintenance Zone Manager or Supervisor			
Utility Supervisor			
Others as Needed			

Client Approvals (Per Approval Matrix):

Organizations Affected by Work, Interruption, or Outage						
Client	Building(s)	Key Contact	Approval Date			

Facilities Management Approvals (Per the Approval Matrix)

			F	acilitie	es Manageme	ent			
Maintenance			Utility and Energy			Design & Construction			
Approval Required?	Approved By:	Date	Appro- Require		Approved By:	Date	Approval Required?	Approved By:	Date
Campus	Services/Land	dscape							
Approval Required?	Approved By:	Date							
			F	or Lite	Safety Syste	ms			
University Engineer			Risk Management and Safety						
Approval Required?	Approved By:	Date	Approval Required?		Approved By:	Date			
				Work	Managemen	t			
Received By: Date		Date	Received Time Received			Date Notice Issued		Time Issued	

Page 2 of 3 R7 7/31/2021

From: Fred Buchanan

Sent: Thursday, August 7, 2025 10:52 AM

To: John Bumpers

Cc: Bob Hix; Nolan Yon; Josh Conradson; Jonathan Haney; Travis Tally **Subject:** Re: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11/25-08/13/25

Attachments: 23-390 - AUHCC - Fire Sprinkler Outage - 25.08.11-08.13.pdf; 23-390 - AUHCC - L1 Fire

Watch Plan.pdf

I approve Fred

Sent from my iPhone

On Aug 7, 2025, at 9:53 AM, John Bumpers <jkb0007@auburn.edu> wrote:

Good morning, everyone -

In addition to the fire alarm outage submitted earlier, the contractor would also like to schedule a fire sprinkler outage for Monday, 08/11, through Wednesday, 08/13, next week at the AU Hotel and Conference Center. This outage is needed so that sprinkler heads can be turned upwards in the laundry room and offices as the ceiling is demoed.

The sprinkler outage would affect only the 1st floor of the building, and the plan is to drain the system at 7:00am and re-energize by 5:00pm each day individually. They may only need to drain the system one or two days out of the three we are scheduling.

The contractor will also be required to have an individual assigned to fire watch duty during this outage when the system is drained, and the attached fire watch plan and sign off sheet will be used for that.

Reach out at my cell or email if you have any questions about this one, or if any changes to the fire watch plan are needed. If this outage is approved, please respond to this email with your approval.

Thank you!

John Bumpers

Project Manager – Construction Management **Auburn University Facilities Management** 1161 W Samford Ave, Auburn University, AL 36849 C: 334.734.1465 | JKB0007@auburn.edu

From: Josh Conradson

Sent: Friday, August 8, 2025 4:46 PM

To: Bob Hix; John Bumpers; Nolan Yon; Jonathan Haney

Cc: Travis Tally; Fred Buchanan

Subject: RE: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11/25-08/13/25

John,

Maintenance approves this outage.

Joshua R. Conradson, M.Ed, PMP, CEFP

Director of Maintenance

Auburn University Facilities Management 1161 W Samford Ave, Auburn University, AL 36849 C: 334-740-8218 | conrajr@auburn.edu

From: Bob Hix <hixjame@auburn.edu> Sent: Friday, August 8, 2025 4:42 PM

To: John Bumpers <jkb0007@auburn.edu>; Nolan Yon <yonbenj@auburn.edu>; Josh Conradson <conrajr@auburn.edu>;

Jonathan Haney <haneyjd@auburn.edu>

Cc: Travis Tally <tallytp@auburn.edu>; Fred Buchanan <buchaf1@auburn.edu> **Subject:** RE: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11/25-08/13/25

Approved.

Please install reflectors above devices that are not near the deck.

Bob Hix, P.E.

C: 334-740-8247 | bobhix@auburn.edu

From: John Bumpers < jkb0007@auburn.edu > Sent: Thursday, August 7, 2025 9:53 AM

To: Bob Hix <hixjame@auburn.edu>; Nolan Yon <yonbenj@auburn.edu>; Josh Conradson <conrajr@auburn.edu>;

Jonathan Haney < haneyjd@auburn.edu >

Cc: Travis Tally <tallytp@auburn.edu>; Fred Buchanan <buchaf1@auburn.edu>

Subject: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11/25-08/13/25

Good morning, everyone -

In addition to the fire alarm outage submitted earlier, the contractor would also like to schedule a fire sprinkler outage for Monday, 08/11, through Wednesday, 08/13, next week at the AU Hotel and Conference Center. This outage is needed so that sprinkler heads can be turned upwards in the laundry room and offices as the ceiling is demoed.

From: Andrew Spurlin

Sent: Friday, August 8, 2025 5:00 PM

To: John Bumpers

Subject: Re: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11-08/13

Thanks, John

Approved for transmittal to work management!

Andrew Spurlin
Auburn University

Sent on the go, please excuse any errors.

From: John Bumpers <jkb0007@auburn.edu> Sent: Friday, August 8, 2025 4:52:33 PM To: Andrew Spurlin <jas0250@auburn.edu>

Subject: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11-08/13

Hey Andrew -

Apologies for the late Friday outage here, but I just got the last approvals for this fire sprinkler outage for the AU Hotel Laundry project. This one will involve draining the sprinkler each day, Monday through Wednesday next week, 7am to 5pm each day. Carlisle will have someone assigned to fire watch as well.

Please let me know if you have any questions about this one, and if this one is approved, then I'll get it submitted to Work Management!

Thanks,

John Bumpers

Project Manager – Construction Management **Auburn University Facilities Management** 1161 W Samford Ave, Auburn University, AL 36849 C: 334.734.1465 | JKB0007@auburn.edu

From: Bob Hix

Sent: Friday, August 8, 2025 4:42 PM

To: John Bumpers; Nolan Yon; Josh Conradson; Jonathan Haney

Cc: Travis Tally; Fred Buchanan

Subject: RE: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11/25-08/13/25

Approved.

Please install reflectors above devices that are not near the deck.

Bob Hix, P.E.

C: 334-740-8247 | bobhix@auburn.edu

From: John Bumpers <jkb0007@auburn.edu> Sent: Thursday, August 7, 2025 9:53 AM

To: Bob Hix <hixjame@auburn.edu>; Nolan Yon <yonbenj@auburn.edu>; Josh Conradson <conrajr@auburn.edu>;

Jonathan Haney haneyjd@auburn.edu

Cc: Travis Tally <tallytp@auburn.edu>; Fred Buchanan <buchaf1@auburn.edu>

Subject: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11/25-08/13/25

Good morning, everyone -

In addition to the fire alarm outage submitted earlier, the contractor would also like to schedule a fire sprinkler outage for Monday, 08/11, through Wednesday, 08/13, next week at the AU Hotel and Conference Center. This outage is needed so that sprinkler heads can be turned upwards in the laundry room and offices as the ceiling is demoed.

The sprinkler outage would affect only the 1st floor of the building, and the plan is to drain the system at 7:00am and re-energize by 5:00pm each day individually. They may only need to drain the system one or two days out of the three we are scheduling.

The contractor will also be required to have an individual assigned to fire watch duty during this outage when the system is drained, and the attached fire watch plan and sign off sheet will be used for that.

Reach out at my cell or email if you have any questions about this one, or if any changes to the fire watch plan are needed. If this outage is approved, please respond to this email with your approval.

Thank you!

John Bumpers

Project Manager – Construction Management **Auburn University Facilities Management** 1161 W Samford Ave, Auburn University, AL 36849 C: 334.734.1465 | JKB0007@auburn.edu

From: Jonathan Haney

Sent: Friday, August 8, 2025 10:50 AM

To: John Bumpers

Subject: RE: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11/25-08/13/25

Approved

Spoke to Terry with Brendle and he said he has it on his schedule.



Jon Haney '08

Specialist III, Safety & Health Risk Management & Safety 1161 W Samford Ave, RMS Bldg 9 O: 334.844.4870 | M: 334.750.9981

haneyjd@auburn.edu cws.auburn.edu/rms



From: John Bumpers <jkb0007@auburn.edu>

Sent: Thursday, August 7, 2025 9:53 AM

To: Bob Hix <hixjame@auburn.edu>; Nolan Yon <yonbenj@auburn.edu>; Josh Conradson <conrajr@auburn.edu>;

Jonathan Haney <haneyjd@auburn.edu>

Cc: Travis Tally <tallytp@auburn.edu>; Fred Buchanan <buchaf1@auburn.edu>

Subject: 23-390 - AUHCC - Fire Sprinkler Outage - 08/11/25-08/13/25

Good morning, everyone -

In addition to the fire alarm outage submitted earlier, the contractor would also like to schedule a fire sprinkler outage for Monday, 08/11, through Wednesday, 08/13, next week at the AU Hotel and Conference Center. This outage is needed so that sprinkler heads can be turned upwards in the laundry room and offices as the ceiling is demoed.

The sprinkler outage would affect only the 1st floor of the building, and the plan is to drain the system at 7:00am and re-energize by 5:00pm each day individually. They may only need to drain the system one or two days out of the three we are scheduling.

The contractor will also be required to have an individual assigned to fire watch duty during this outage when the system is drained, and the attached fire watch plan and sign off sheet will be used for that.

Reach out at my cell or email if you have any questions about this one, or if any changes to the fire watch plan are needed. If this outage is approved, please respond to this email with your approval.

Thank you!