First Floor Outage 8/15/16 to 8/26/16

Second Floor Outage 8/29/16 to 9/9/16

ThirdFloor Outage 9/12/16 to 9/23/16



PARTIAL FIRST FLOOR PLAN
PLUMBING - PRESSURE PIPING
0 2 4 6 8 16



PARTIAL SECOND FLOOR PLAN
PLUMBING - PRESSURE PIPING
0 2 4 6 8 16



PARTIAL THIRD FLOOR PLAN
PLUMBING - PRESSURE PIPING
0 2 4 6 8 16

WATER HEATER SCHEDULE

SYMBOL	MANUFACTURER	MODEL	SYSTEM	QTY.	FUEL	EWT	LWT	GALLON STORAGE	FLOW REC.	REMARKS
DWH-1	EEMAX	NT0102401	DOMESTIC	8	7KW/208V/1PH	80°F	105°F (MAX.)	N/A	0.30-2.0GPM	WALL MOUNTED

FIXTURE CONNECTION SCHEDULE

ITEM	DESCRIPTION	WATER COLD	WATER HOT	WASTE	VENT	REMARKS
P-1	LAVATORY FAUCET	1/2"	1/2"	---	---	EXISTING LAVATORY

P-1: ZURN AQUASENSE ZER70-XL-F OR SIMILAR. 0.5GPM VANDAL RESISTANT AERATOR, BATTERY OPERATED, SENSOR FAUCET.

15-030 Thach Hot Water project outage request.



DETAIL
TYPICAL PUBLIC TOILET LAVATORY INSTALLATION DETAIL
NO SCALE



KEY PLAN
NO SCALE

AUBURN UNIVERSITY
Facilities Management
1161 West Samford Avenue
Auburn University, AL 36849
Phone: (334) 844-4810
Fax: (334) 844-9458

Safety is our first priority. Think Safety. Act Safely.

No.	Revision	Date

04/15/16

Thach Hall - V-03-03
Provide Hot Water for Public Restrooms
Auburn University Project Number 15-030

SHEET TITLE: PLUMBING DETAILS, SCHEDULES AND PARTIAL FLOOR PLANS

DRAWN BY: JTG
CHECKED BY: JJR
DATE: 04-15-16
FILE NUMBER: 5218P01.DWG
PROJECT NUMBER: AU # 15-030
SHEET NUMBER: P1.0
3 of 5