




Prepared for
Auburn University
Auburn, Alabama



235 Peachtree Street, Suite 500, Atlanta, GA 30303
 Office: 404 439-9000
 Fax: 404 439-9001
 Internet: <http://www.bick.com>

reproduction and editorial property rights reserved © 2002
in association with:

Newcomb & Boyd
CLP Engineers
303 Peachtree Center Ave NE, Suite 525
Atlanta, GA 30303-1277



no.	Issue Description	Date
	FOR CONSTRUCTION	04/15/05
	ADDENDUM 1	05/09/05
	ADDENDUM 2	05/20/05
	CONFORMED SET	06/30/05
	RFI-273	09/21/06
	RFI-458	04/24/07
	RECORD DRAWINGS UPDATE	05/31/07
	RFI #556	09/11/07
	AS-BUILT DRAWINGS	02/09/08


Reviewed by:	NAM	Reviewed by:	ICD
Test No:	0.3-0076-00		

LEVEL 0
ACTION B
POWER PLAN

According to 34° x 100°, boats will be accordingly if required

E200B

- ① LIGHT SWITCH TO BE MOUNTED 60" ABOVE THE FIRST FLOOR LANDING ELEVATOR SILL.
- ② A MINIMUM OF 7'-0" CLEAR HEIGHT SHALL BE MAINTAINED IN THE ELEVATOR ROOM. ONLY ITEMS PERTAINING TO THE OPERATION OF THE ELEVATOR ARE ALLOWED IN THE ELEVATOR HOISTWAY AND MACHINE ROOM.
- ③ MAIN SWITCHBOARD "XGB".
- ④ PS
- ⑤ GROUND BUS "GBA". SEE DETAIL 1/403.
- ⑥ TRANSFORMER "XHB".
- ⑦ PANEL "LBA" WITH TRANSFORMER "XELBA" MOUNTED ABOVE. SEE DETAIL 1/3607.
- ⑧ LIGHTING CONTACTOR "LCBA".
- ⑨ PANEL "LGB" WITH TRANSFORMER "XELGB" MOUNTED ABOVE. SEE DETAIL 1/3507.
- ⑩ PANEL "TBA".
- ⑪ TRANSFORMER "XLB".
- ⑫ PANEL "HBA".
- ⑬ PANEL "TBA".
- ⑭ PANEL "EGBA".
- ⑮ TRANSFER SWITCH "LSA".
- ⑯ TRANSFER SWITCH "TA".
- ⑰ PANEL "EGBA".
- ⑱ PANEL "HGB".
- ⑲ RECEPTACLES FOR ELECTRIC WATER COOLER.
- ⑳ WATER COOLER ENCLOSURE.
- ㉑ 60/2F/2E ENCLOSURE FOR WATER HEATER.
- ㉒ 2 #6, 1 #10 G., 3/4" C.
- ㉓ GROUND BUS "GGBA".



1 FLOOR PLAN - LEVEL 0 - SECTION B

RECORD CONSTRUCTION DRAWING

THIS DRAWING REPRESENTS A RECORD OF THE PROJECT DESIGN AND CONSTRUCTION GENERAL INFORMATION REGARDING AS-INSTALLED CONDITIONS PROVIDED BY THE CONTRACTOR HAS BEEN INCORPORATED INTO THIS DRAWING, BUT THE ACCURACY AND COMPLETENESS OF THAT INFORMATION HAS NOT BEEN VERIFIED. REFER TO THE CONTRACTOR'S RECORD SHOP DRAWINGS FOR EXACT SYSTEMS INFORMATION.

NY 62-75741-394 107-
8002/21/9-7-63 107-
BT AB 4074
0036/26/21-2620\10 076